



| PANDUIT<br>PART NUMBER | STUD<br>SIZE | DIMENSIONS in. |               |               |                |                |
|------------------------|--------------|----------------|---------------|---------------|----------------|----------------|
|                        |              | A $\pm .020$   | W $\pm .010$  | C $\pm .015$  | M $\pm .020$   | H $\pm .005$   |
| P14-6FF                | #6           | .65<br>(16.51) | .28<br>(7.11) | .22<br>(5.59) | .49<br>(12.45) | .160<br>(4.06) |
| P14-8FF                | #8           | .72<br>(18.29) | .31<br>(7.87) | .25<br>(6.35) | .53<br>(13.46) | .173<br>(4.39) |

## NOTES:

- UL LISTED AND CSA CERTIFIED FOR:
  - #16-14 AWG SOLID OR STRANDED COPPER WIRE
  - 347° F (175° C) MAX. TEMP. RATING
- MATERIAL:
  - STAMPING - .03" (.76) THK COPPER, TIN PLATED
- PACKAGE QTY: STD. PKG. 100  
BULK PKG. 1000
- DIMENSIONS IN BRACKETS ARE IN MILLIMETERS
- INSTALLATION TOOLS: CT-100, CT-160, CT-200



LISTED  
587H  
E52164



CERTIFIED  
LR31212

A41237\_05

|     |       |     |     |                                             |       |     |     |                                                                                                                                                      |       |               |                       |
|-----|-------|-----|-----|---------------------------------------------|-------|-----|-----|------------------------------------------------------------------------------------------------------------------------------------------------------|-------|---------------|-----------------------|
| 05  | 11/01 | SAB |     | THE TOLERANCE FOR DIMENSION H WAS $\pm .01$ |       |     |     |  <b>PANDUIT</b> <b>CORP.</b> <span>TINLEY PARK, ILLINOIS</span> |       |               |                       |
| 04  | 10/01 | SAB | SKB | DIMENSION H FOR P14-6FF WAS .15, (3.81)     | 09712 | BAD | LA  |                                                                                                                                                      |       |               |                       |
| 03  | 1/01  | RM  | SKB | FILESPEC WAS A41237A::1:L1                  | 08937 | CCH | JAC |                                                                                                                                                      |       |               |                       |
| 2   | 7-88  | DW  |     | REDRAWN WITH REVISIONS                      |       |     |     |                                                                                                                                                      |       |               |                       |
| REV | DATE  | BY  | CHK | DESCRIPTION                                 | ECN # | PM  | APP | DRAWN BY<br>DAW                                                                                                                                      | CHK'D | SCALE<br>NONE | DRAWING NO.<br>A41237 |

#16-14 BARREL NON-INSULATED  
FLANGED FORK

# AMEYA360

## Components Supply Platform

Authorized Distribution Brand :



Website :

Welcome to visit [www.ameya360.com](http://www.ameya360.com)

Contact Us :

➤ Address :

401 Building No.5, JiuGe Business Center, Lane 2301, Yishan Rd  
Minhang District, Shanghai , China

➤ Sales :

Direct +86 (21) 6401-6692

Email [amall@ameya360.com](mailto:amall@ameya360.com)

QQ 800077892

Skype ameyasales1 ameyasales2

➤ Customer Service :

Email [service@ameya360.com](mailto:service@ameya360.com)

➤ Partnership :

Tel +86 (21) 64016692-8333

Email [mkt@ameya360.com](mailto:mkt@ameya360.com)